

As a reminder, the Advertisement specifically identifies **RULES OF CONTACT** that apply during the contract selection process, commencing on the advertisement posting date and ceasing at the time of final contract selection. **Any contact determined to be improper, at the sole discretion of DOTD, may result in the rejection of the proposal (i.e., DOTD Form 24-102).**

Please note, all questions received by DOTD are not necessarily answered, only those questions deemed by DOTD to enhance or clarify the advertisement will be addressed.

**CONTRACT NO. 4400020019
ENTITY CONTRACT FOR ST. MARY STREET SIDEWALKS
STATE PROJECT NO. H.011833
F.A.P. NO. H011833
LAFAYETTE PARISH**

Question and Answer

September 1, 2020:

- Q1. The available apparent existing roadway right of way appears to be very limited along much of the route for construction of proposed sidewalks. Are the proposed sidewalks to be constructed within the existing right of way?
- A1. **The intent is to stay within the existing right-of-way.**
- Q2. The Scope of Services in Attachment A includes “subsurface drainage work where needed”. Does “where needed” mean only where required to facilitate construction of the proposed sidewalks?
- A2. **Yes.**
- Q3. There are no drainage outfall laterals along the route for the subsurface storm drainage system to discharge into. Will the proposed “subsurface drainage work” consist of simply matching existing drainage structure type, size and elevation or will a typical complete DOTD subsurface storm drainage analysis and design be required?
- A3. **Subsurface drainage analysis and design will be done as needed to facilitate the construction of the sidewalk. A complete analysis and design will not be required.**